



Condition	
Cooling	
Indoor DB	24.0 °C
Humidity	47 %
Indoor WB	16.6 °C
Outdoor DB	35.0 °C
Heating	
Indoor DB	20.0 °C
Outdoor DB	-20.0 °C
Humidity	100 %
Outdoor WB	-19.9 °C